



Österreichische Vereinigung für das Gas- und Wasserfach
A-1010 Wien, Schuberttring 14
Telefon: +43 / 1 / 513 15 88-0* / Telefax: +43 / 1 / 513 15 88-25
E-Mail: office@ovgw.at / Internet: www.ovgw.at



Accredited by the Federal Ministry
of Science, Research and Commerce



ÖVGW Certificate

of the conferment of the right to use
the ÖVGW Quality Mark for Water

Registration number

W 1.128

Period of validity

until the end of March 2019

Owner ♦ Distribution in Austria

E. Hawle Armaturenwerke GmbH
Wagrainerstraße 13
4840 Vöcklabruck

Manufacturer

E. Hawle Armaturenwerke GmbH / AT

Type of test

Renewal test

Test report

TGM - VA HL 8389 dated 28 June 2016

Quality standards / Testing directives

- QS-W 501/1 version December 2014
in combination with ÖNORM Standards
EN 1074-1 and EN 1074-2 as well as
QS-W 300, Annex A.2, version August 2015
(ISO 14236)

Product

House connection slider made of POM
(soft-sealing wedge gate valve)

for the drinking water supply system
with cold water, PN 16

Type: **2630**

DN/d_n 15/20, 20/25, 25/32, 32/40, 40/50, 50/63

on both sides with ISO pipe sleeve for PE pipes

The conferment is based on the General Terms and Conditions GW 30 ÖVGW Quality Mark for Gas & Water Products
"Conditions for the award of the ÖVGW Quality Mark for gas and water supply products."

Vienna, 7 July 2016

Dipl.-Ing (FH) Alexander Schwanzer
Head of the ÖVGW Certification Office