



1	Corrugated wall
2	Oil Level Indicator
3	Oil filling valve
4	Lifting lugs
5	Earthing terminal
6	Oil sampling & drain valve
7	H.V Bushings
8	L.V. Bushings(without flag)
9	Rating plate
10	Tap changer
11	Bracket
12	Surge Arrester Mounting Bracket
Active Part Weight = 440 kg	
Oil Weight = 160 kg	
Total Weight = 670 kg	



ALL WEIGHTS AND DIMENSIONS HAVE +/- %10 TOLERANCES



App./Onay				Kritiklik sınıfı /Criticality Class:
Checked /Kontrol	Samet BALCI	8.12.2020		
Drawn/Çizen	Ergün ÇETINKAYA	8.12.2020		Tolerans sınıfı / Tolerance Class:
	Adı Soyadı/Name Surname	Tarih/Date	İmza/Sign	ISO 2768-c
	Malzeme/Material	Kaplama/Coat:	Renk/Color:	Parça Adı/Part Name:
SERTLİK/HARDNER:		Sac Kalın./ Sheet Thic.: -mm	Adet/Tk. Qty/Ass.: -	
ÖLÇEK/SCALE 1:15	Kontrol ölçüleri/ Control Dimensions	Weight/ Ağırlık:	-kg	SHEET 1 OF 1

ULUSOY ELEKTRİK
İMALAT TAAHHÜT
TİCARET A.Ş.



YT-1141-100 KVA 20,5-0,41 KV-GENERAL
ARRANGEMENT DRAW.

A4

STOK NO: