


1	Corrugated wall
2	Oil Level Indicator
3	Oil filling valve
4	Lifting lugs
5	Earthing terminal
6	Oil sampling & drain valve
7	H.V Bushings
8	L.V. Bushings(without flag)
9	Rating plate
10	Tap changer
Active Part Weight = 750 kg	
Oil Weight = 240 kg	
Total Weight = 1110 kg	



ALL WEIGHTS AND DIMENSIONS HAVE +/- %10 TOLERANCES

App./Onay				Kritiklik sınıfı /Criticality Class:
Checked /Kontrol	Samet BALCI	7.12.2020		
Drawn/Çizen	Onur SAĞLAM	7.12.2020		Tolerans sınıfı / Tolerance Class:
	Adı Soyadı/Name Surname	Tarih/Date	İmza/Sign	ISO 2768-c
	<u>Malzeme/Material</u>	<u>Kaplama/Coat:</u>	<u>Renk/Color:</u>	Parça Adı/Part Name:
SERTLİK/HARDNER:		Sac Kalın./ Sheet Thic.: -mm	Adet/Tk. Qty/Ass.: -	
ÖLÇEK/SCALE 1:17	Kontrol ölçüleri/ Control Dimensions	Weight/Ağırlık: -kg	SHEET 1 OF 1	STOK NO:

**ULUSOY ELEKTRİK**  
İMALAT TAAHHÜT  
TİCARET A.Ş.



YT-1146-200 kVA 20,5-0,41 kV-GENERAL  
ARRANGEMENT DRAW.

A4