

LÜDECKE

Lüdecke GmbH, Heinrich-Hauck-Straße, 92224 Amberg

INSPECTION CERTIFICATE

EN 10 204 - 2.1

Customer: Würth Oy (Ltd) Würthintie 1 FI-11710 Riihimäki	No.: 211615
Order no.:	Date: 29.08.2019

Description of article: Claw couplings made of stainless steel according to DIN 3489 Max. pressure: PN 16 bar Max. temperature: -30°C - +200°C Threads: ISO 228	Material: Couplings: stainless steel 1.4401 Sealing rings: FKM
--	---

Purchased materials and components are clearly defined by exact specifications and drawings. Delivered goods are subject to an incoming inspection. The products manufactured in-house are subject to a permanent quality check and a systematic quality control. There is a CAQ-SPC measuring station at our disposal for quality control. Our quality service supervises the qualitatively and quantitatively correct execution.

Amberg, 29/08/2019



Michael Morin

LÜDECKE GmbH
Heinrich-Hauck-Straße 2
92224 Amberg
Tel. 09621 / 76 82-0 · Fax 09621 / 76 82-99
info@luedecke.de

Stamp