



Product Service

# CERTIFICATE

No. B 099070 0008 Rev. 00

**Holder of Certificate:** Etman Electric(Changzhou)Co.,Ltd.  
6 Miaoban Road, Lijia District  
213165 Changzhou, Jiangsu Prov.  
PEOPLE'S REPUBLIC OF CHINA

**Certification Mark:**



**Product:** **Sockets**  
**Fixed Socket-outlet with USB charger**

**Model(s):** **ETM703PQ, ETM703BQ, ETM703UQ,**  
**ETM703XQ, ETM703EQ, B703Q, U703Q, E703Q**

**Parameters:**

Rated voltage:	250V~
Rated frequency:	50Hz
Rated current:	16A
Protection class:	I
Degree of protection:	IP20
Method of installation:	Flush-type
USB charger output:	Output Single A-port or Output Single C-port: 5.0VDC 3.0A, 15.0W; 9.0VDC 2.0A, 18.0W; 12.0VDC 1.5A, 18.0W; Output A-port + Output C-port: 5.0VDC 3.0A, 15.0W (3.0A in total);

**Tested according to:** IEC 60884-1:2002  
IEC 60884-1:2002/AMD1:2006  
IEC 60884-1:2002/AMD2:2013  
EN 62368-1:2014/A11:2017  
SFS 5610:2015/A11:2016  
NEK 502:2016  
SS 428 08 34:2013/T1:2018  
DS 60884-2-D1:2017

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 704102001219-01  
**Valid until:** 2026-08-26

**Date,** 2021-08-27

( Jie Zhu )