

The maximum permitted joint/gap width for system TYTAN B1 Fire acryl is 100 mm.

3.3 The system TYTAN B1 Fire acryl may be used to provide a penetration seal with specific single insulated metal pipes, uninsulated metal pipes, plastic pipes and with specific electrical cables, single or in a bundle and may also be used to provide a linear joint or gap seal with specific supporting constructions and substrates (for details see ETA 13/0879 and 13/0880 Annex A).

resistance period.

The supporting construction must be classified in accordance with EN 13501-2 for the required fire

concrete with a minimum density of 650 kg/m³.

Rigid floors: The floor must have a minimum thickness of 150 mm and comprise aerated concrete or

concrete or masonry, with a minimum density of 650 kg/m³.

Rigid walls: The wall must have a minimum thickness of 150 mm and comprise concrete, aerated

both faces with minimum 2 layers of 12.5 mm thick boards.

Flexible walls: The wall must have a minimum thickness of 100 mm and comprise steel studs lined on

a gap or joint seal or penetration seal in, are as follows:

3.2 The specific elements of construction that the system TYTAN B1 Fire acryl may be used to provide

services with and without combustible insulation, plastic pipes and electrical cables.

3.1 The intended use of system TYTAN B1 Fire acryl is to reinstate the fire resistance performance of gaps in and joints in and between flexible wall constructions, gaps in and joints between rigid floor constructions and rigid floor constructions where they are penetrated by various metal pipe rigid wall constructions and without combustible insulation, plastic pipes and electrical cables.

ETAG 026-2 (penetration seals):

European Assessment Document (Hereinafter EAD):

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer, and in accordance with the applicable

batch number: see packaging of the product

required pursuant to article 11(4):

2. Type, batch or serial no. or any other element allowing identification of the construction product as

TYTAN PROFESSIONAL B1 Fire acryl

1. Unique identification code of the product-type:

according Annex III of the Regulation (EU) No 305/2011 nr F500000001
Edition: 01.23.2015



DECLARATION OF PERFORMANCE



The maximum movement capability of system TYTAN B1 Fire acryl is $\leq 7.5\%$

Pipes shall be supported at maximum 350 mm away from both faces of the wall constructions and from the upper face of floor constructions.

3.4 The provisions made in this DOP are based on an assumed working life of the TYTAN B1 Fire acryl of 10 years, provided that the conditions laid down in sections 4.2/5.1/5.2 for the packaging/transport/ storage/installation/use/repair are met. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

3.5 Type Z2: Intended for uses in internal conditions with humidity lower than 85 % RH excluding temperatures below 0°C, without exposure to rain or UV.

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to article 11(5):

Selena FM S.A.
Ul. Strzegomska 2-4
53-611 Wrocław
Poland

5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):

Not applicable

6. System or systems of assessment and verification of consistency of performance of the construction product as set out in annex V:

AVCP-System 1

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

Not applicable

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

This Declaration of Performance has been prepared in accordance with the guidelines set out within ETAG 026 part 1 and 3 (linear joint, gap seals and penetration seals).

ETA 13/0879 and ETA 13/0880 prepared by UL International (UK) Ltd notified body 0843

EC Certificate of conformity 0843-CPD-0139.

9. Declared performance:

Product –type: Intumescent sealant	Intended use: Linear Joint & Gap Seal, Penetration Seal	
Essential characteristics	Performance	Test Standard
Reaction to Fire	NPD	EN 13501-1
Resistance to Fire	ETA 13/0879 Annex A	EN 13501-2
Air permeability (material property)	NPD	EN 1026:2000
Water permeability (material property)	Not water proof	ETA G 026-3 Annex C
Release of dangerous substances	EC 1 plus	GEV/EMICODE
Mechanical Resistance and stability	NPD	EOTA TR 001:2003
Resistance to impact/movement	NPD	EOTA TR 001:2003
Airborne sound insulation	Rw = 62dB @ 12mm depth single sided w/o backing	EN 10140-2
Impact sound insulation	NPD	EN 10140-3
Thermal properties	0,0845 W/mK (+/- 3%) @ 20mm depth	EN 12664, EN12667, or EN12939
Water vapour permeability	NPD	EN ISO 12572, EN 12086
Durability and serviceability	Z ₂	ISO 8339:2005, ISO 9046:2004 & ISO 7389
Tensile Properties	Elongation at break ≥ 100% @23°C	ETA G 026 pt2 B.13.5 ISO
Elastic recovery	7.5% Elongation 50% recovery, M2 Mortar	ETA G 026 pt2 B.13.5 ISO
Adhesion properties	No failure, M2 Mortar	ETA G 026 pt2 B.13.5 ISO 9046:2005

10. The performance of the product identified in points 1 and 2 is in conformity with the performance in point 9.
This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed on the behalf of the manufacturer by:

Remigiusz Cybulski
Leader of Chemical Regulation and Technical Documentation

23.01.2015 Wrocław