

CERTIFICATE

KEMA No.: 2006285.01

Issued to:
Applicant:
WISKA Hoppmann & Mulsow
Kisdorfer Weg 28
KALTENKIRCHEN, Germany

Manufacturer/Licensee:
WISKA Hoppmann & Mulsow
Kisdorfer Weg 28
KALTENKIRCHEN, Germany

Product : square cable boxes

Trade name : WISKA
Type/model : COMBI/607

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

KEMA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard IEC 60670:1989
- an inspection of the production location according tot CCA Group Operational Document CCA 204
- a certification agreement with the number 900947.

KEMA hereby grants the right to use the KEMA certification mark



The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: October 30, 2000

C.M. Boschloo
Certification Manager

© Integral publication of this certificate is allowed



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product : square cable boxes
trade name : WISKA
type : COMBI/607

Product data - type COMBI/607

with membrane for cable and also in :
combination
with cable glands ESKV : IP66/67

TESTS**Test requirements**

- K132 W1 (based on IEC 60670 2nd Edition 1989) and
- NBN C 68 685-1, 3rd ed. 1990 and Am.1.

Test result

The test results are laid down in KEMA test file no. 2006285.01A.

Conclusion

The examination proved that all test requirements were met.

Tested by : H. Sablan 

Checked by : R. van Daalen 

Factory-Location

WISKA Hoppmann & Mulsow, Elektrotechnische Fabrik
Kisdorfer Weg 28, Kaltenkirchen, Germany

KEMA Registered Quality B.V.

Utrechtseweg 310, 6812 AR Arnhem, The Netherlands
P.O. Box 9035, 6800 ET Arnhem, The Netherlands
Telephone +31 26 3 56 28 50, Telefax +31 26 3 52 58 00

List of components

component	trade name	type/model	approval mark ¹⁾
Cable gland M25 x 1,5	WISKA	ESKV 25(for cables with a diameter of 9 - 17 mm).	*

¹⁾ * indicates a component tested as part of the appliance