

K 22839/01 Repla

2003-01-01


Product Certificate
Thermostatic control valves

Based on pre-certification tests as well as periodic inspections by Kiwa, the products referred to in this certificate and marked with the Kiwa-mark as indicated under 'Marking', manufactured by

Danfoss B.V.

may, on delivery, be relied upon to comply with the Kiwa evaluation guideline BRL-K14003 "Thermostatic control valves".

Kiwa N.V

A handwritten signature in black ink, appearing to read "B. Meekma", written over a light blue rectangular background. A horizontal line is drawn below the signature, and a small checkmark is visible below the line.

ing. B. Meekma
Director,
Certification and Inspection

This certificate is issued in accordance with the Kiwa-Regulations for Product Certification and consists of 2 pages.

Publication of the certificate is allowed.

*) This is a translation. Only the Dutch text is legally binding.

Kiwa N.V.
Certification and Inspection

Postbus 70
280 AB Rijswijk
The Netherlands

Telephone +31 70 41 44 400
Telefax +31 70 41 44 420

Company

Danfoss B.V.
Admiraal Lucashof 3
3115 HM SCHIEDAM
Netherlands
Phone +31 10 2492000
Fax +31 10 2492001
e-mail : klimaatregeltechniek@danfoss.
website: www.danfossverwarming.nl

Thermostatic control valves

PRODUCT SPECIFICATION

Thermostatic control valves

- MCTV DN 15
- MCTV DN 20

APPLICATION AND USE

De products are to be used in hot water circulation systems in water waterinstallations, with a working pressure up to a maximum of 1000 kPa and a water temperature up to a maximum of 90°C.

After adjusting the product, a prior to installation set temperature, minimum temperature upstream the control valve will be maintained while maintaining the hydraulic balance.

MARKING

The products are marked with the Kiwa-mark.

Place of the mark:
on the product

Compulsory specifications:
on the body

- direction of flow
- nominale size (DN)
- Manufacturer's identification mark

on nut of the compression fitting (if applicable)

- nominal size (DN)
- Manufacturer's identification mark
- production code

Method of marking:

- Non-erasable;
- Visible after installation.

RECOMMENDATIONS FOR CUSTOMERS:

Check at the time of delivery whether:

- 1.1 the producer has delivery in accordance with the agreement;
- 1.2 the mark and the marking method are correct;
- 1.3 the products show no visible defects as a result of transport etc.
2. If you should reject a product on the basis of the above, please contact:
 - 2.1 Danfoss BV
and, if necessary,
 - 2.2 Kiwa N.V.
3. Consult the producer's processing guidelines for the proper storage and transport methods.
4. Check whether this certificate is still valid by consulting the Kiwa website (www.kiwa.nl).