

DECLARATION OF PERFORMANCE

DoP Nr/ n°: DoP-004/2018



Unique identification code of the product-type:

AXMK

Intended use/s:

Supply of electricity in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke

Authorized representative: N/A

System/s of AVCP: System 3

Harmonized standard: EN 50575:2014 and EN 50575:2014/A1: 2016

Notified body/ies: 1014 Electrotechnical Testing Institute

Notified testing laboratory carrying out the determination of the product type for characteristics of reaction to fire.

Test Report Reference: 704619 - 01/01, 703964 - 01/01, 703964 - 01/02

Date of Test Report: 12.01.2018, 15.01.2018

Declared performances:

Essential characteristics	Performance
Reaction to fire	Eca
Dangerous substances	NPD

The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Yuri Astrouski
Head of Quality

A handwritten signature in blue ink, appearing to read 'Yuri Astrouski', is placed over the printed name and title.

Vitebsk
Republic of Belarus
15.01.2018