












Panasonic

Model name		SEER 						SCOP 																
								Warmer 					Average 					Colder 						
Indoor Unit	Outdoor Unit	A ~ G	kW	SEER	*2 kWh/annu m	 dB	 dB	A ~ G	kW	SCOP	*2 kWh/annu m	elbu (2°C) kW	A ~ G	kW	SCOP	*2 kWh/annu m	 dB	 dB	elbu (-10°C) kW	A ~ G	kW	SCOP	*2 kWh/annu m	elbu (-22°C) kW
S-25PY3E	U-25PZ3E5	A++	2.5	6.5	134	46	64	-	x	x	x	x	A++	2.8	4.6	850	46	66	0.00	-	x	x	x	x
S-36PY3E	U-36PZ3E5	A++	3.6	6.7	188	49	64	-	x	x	x	x	A+	2.8	4.3	912	49	66	0.00	-	x	x	x	x
S-50PY3E	U-50PZ3E5	A++	5.0	7.3	238	54	64	-	x	x	x	x	A+	4.0	4.4	1264	54	64	0.00	-	x	x	x	x
S-60PY3E	U-60PZ3E5A	A++	6.0	6.8	305	58	64	-	x	x	x	x	A+	4.6	4.2	1500	58	65	0.00	-	x	x	x	x
S-50PY3E x 2	U-100PZ3E5	A++	10.0	6.2	562	54	70	-	x	x	x	x	A	10.0	3.8	3665	54	70	1.69	-	x	x	x	x
S-50PY3E x 2	U-100PZ3E8	A++	10.0	6.1	569	54	70	-	x	x	x	x	A	10.0	3.8	3665	54	70	1.69	-	x	x	x	x
S-36PY3E	U-36PZH3E5	A++	3.6	7.3	171	49	62	-	x	x	x	x	A++	3.6	4.7	1073	49	64	0.00	-	x	x	x	x
S-50PY3E	U-50PZH3E5	A++	5.0	7.0	248	54	64	-	x	x	x	x	A++	4.5	4.6	1370	54	67	0.23	-	x	x	x	x
S-60PY3E	U-60PZH3E5	A++	6.0	6.7	314	58	65	-	x	x	x	x	A+	4.6	4.3	1498	58	69	0.26	-	x	x	x	x
S-36PY3E x 2	U-71PZH3E5	A++	7.1	6.3	391	49	65	-	x	x	x	x	A+	5.2	4.5	1595	49	67	0.00	-	x	x	x	x
S-50PY3E x 2	U-100PZH3E5	A++	10.0	6.2	561	54	69	-	x	x	x	x	A	8.0	3.9	2838	54	69	0.00	-	x	x	x	x
S-36PY3E x 3	U-100PZH3E5	A++	10.0	6.1	567	49	69	-	x	x	x	x	A	8.0	3.9	2840	49	69	0.00	-	x	x	x	x
S-36PY3E x 2	U-71PZH3E8	A++	7.1	6.2	395	49	65	-	x	x	x	x	A+	5.2	4.5	1596	49	67	0.00	-	x	x	x	x
S-50PY3E x 2	U-100PZH3E8	A++	10.0	6.1	568	54	69	-	x	x	x	x	A	8.0	3.9	2838	54	69	0.00	-	x	x	x	x
S-36PY3E x 3	U-100PZH3E8	A++	10.0	6.1	573	49	69	-	x	x	x	x	A	8.0	3.9	2840	49	69	0.00	-	x	x	x	x

ENERGIA · ЕНЕРГИЈА · ΕΝΕΡΓΕΙΑ · ENERGIJA · ENERGY · ENERGIE · ENERGI

626/2011

R32 (GWP=675) *1

*1

Refrigerant leakage contributes to climate change. Refrigerant with lower global warming potential (GWP) would contribute less to global warming than a refrigerant with higher GWP, if leaked to the atmosphere. This appliance contains a refrigerant fluid with a GWP equal to 675. This means that if 1 kg of this refrigerant fluid would be leaked to the atmosphere, the impact on global warming would be 675 times higher than 1 kg of CO₂, over a period of 100 years. Never try to interfere with the refrigerant circuit yourself or disassemble the product yourself and always ask a professional.

*2

Energy consumption "XYZ" kWh per year, based on standard test results. Actual energy consumption will depend on how the appliance is used and where it is located.