



ITE n.v.
Europark Oost 24
9100 Sint-Niklaas
Belgium
Tel : +32 3 766 02 02
Fax: +32 3 766 10 67

Sint-Niklaas, 11th June 2009

EC DECLARATION OF CONFORMITY

We, ITE n.v. - Europark Oost 24 - 9100 Sint-Niklaas - Belgium, hereby declare that the ITE Leak Detector ITE-XTRA has been manufactured in accordance with the following EC directives:

89/336/EEC

The applied standards are:

EN50270:1999
EN55022
EN61000-4-2/-3

Furthermore: The ITE-XTRA Leak Detector has been tested following the E35-422 and EN 14624 Directives and found completely in accordance with these standards.

The ultimate sensitivity of this leak detector, tested as per above Directives, is between 2 and 4 gram/year for HFC 134a.

Dirk Maes
Technical Director



B.T.W. BE 428.864.021 H.R.SN 47.346