



CERTIFICATE

FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2101725

Junction Box

Type designation: ETM233S, U233, B233, G233

Certificate holder: Etman Electric (Changzhou) Co., Ltd.
6th miaoban Street Wuyang Village, Lijia Town, Wujin District, Changzhou
City Jiangsu 213165, China

The product complies with the standard(s): EN 60670-1: 2005+A1
EN 60670-22: 2006

Date of expiry: 29 December, 2026

EU Directive information: According to the principle of presumption of conformity, this certificate constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification **Place:** Shanghai

Signed:

Date: 29 December, 2021

Hyden Li

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX:

Reference No. SE-S-2101725

Technical Data:

Type designation ETM233S, U233, B233, G233
Rated voltage (V) 400
IP-Class 65
Number of Terminals: 5
Connecting capability(mm²) 1,5-2,5
Trademark



Test Report 211200965SHA-001
Product information Junction/connecting box of insulated material, for surface mounting, with membrane, with incorporated terminal block, see appendix for details.

Appendix to S cert

Junction/connecting box of insulated material, for surface mounting, with membrane for cable diameter 9-15mm (Maximum 7X1,5mm² or 5X2,5mm²), with incorporated terminal block 380V and 2.5mm²
 For type ETM233S, U233, B233 and G233, all is the same, only different type designation according to different trademark

ETM233S with trademark



U233, B233 with trademark

EGANT

G233 with trademark

Globel

Manufacturing Sites:

Etman Electric (Changzhou) Co., Ltd.
 6th miaoban Street Wuyang Village, Lijia Town, Wujin District, Changzhou City
 Jiangsu 213165, China

Safety related parts of the user instructions shall be written in a language acceptable to the country where the product is to be used.

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

This certificate replaces previously issued ref. 1706936, dated 9 February 2017. A new certificate has been issued on account of adding type G233 with new trademark Globel and reassuring one new five-year cert.

Certification Body:

Intertek Semko AB, Product Certification

Place: Shanghai

Signed:

Date: 29 December, 2021

Hyden Li